

Consent Holder	Ravensdown Fertiliser Co-operative Limited	Consent No	DP040143W
Client Address	Private Bag 6012 Hawke's Bay Mail Centre NAPIER 4142	Site Address	808 Waitangi Road, Awatoto
Contact Name	Kevin Gettins	Phone	(06) 834 1760
Job Code	456-06	Mobile	021 900 292
		Consent Type	Discharge Permit

Activity Description:

to discharge contaminants into water for the purpose of disposing of stormwater, cooling water from air compressors and a hydraulic drive, water from drinking fountains and a truck wash, water from cooling towers and high pressure boilers, and rinse water from a boiler water treatment plant into the Tutaekuri River (Waitangi Estuary).

20-Aug-08	Monitoring Report Sent	Officer	Barbara McKenzie
30-Apr-09	Monitoring Inspection	Officer	Jim May

2008-2009 Statement of Compliance and Overall Grades:

Grade Date	26-Jun-09
Environmental Grade	2 Minor non-compliance
Technical Grade	1 Compliance

Overall Comments:

Condition 4 was incorrectly graded. Minor non-compliance with this condition.

Previous Statement of Compliance and Overall Grades:

Grade Date	18-Aug-08
Environmental Grade	2 Minor non-compliance
Technical Grade	1 Compliance

Overall Comments:

Refer to back page for grading information

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
1	Technical	All works and structures relating to this resource consent shall be designed and constructed to conform to the best engineering practices and at all times maintained to a safe and serviceable standard.	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
2	Technical	The consent holder shall undertake all operations in accordance with any drawings, specifications, statements of intent and other information supplied	

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
		as part of the application for this resource consent. If a conflict arises between any conditions of this consent and the application, the conditions of this consent will prevail.	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
3	Environmental	For the purposes of this consent, the zone of reasonable mixing of the discharge, to which the Class AE (HB) receiving water quality standards does not apply, shall be the Ravensdown Drain and 90 m down the Awatoto Drain (GPS Co-ordinates N6175341, E2846875).	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
4	Environmental	<p>The consent holder shall ensure that the discharge complies with the following standards at the outlet of the settling pond, as shown on Figure 3 submitted with the application and attached:</p> <p>a) pH to be within 6.5 – 8.5.</p> <p>b) Fluoride not to exceed 30 mg/litre.</p> <p>c) Suspended Solids not to exceed 100 mg/litre.</p> <p>d) Rate of discharge not to exceed 265 litres /second.</p> <p>e) Total phosphorus:</p> <p>From the date of the commencement of this consent until 30 June 2012:</p> <p><input type="checkbox"/> Over any 12 month period the concentration of total phosphorus shall not exceed 35 mg/litre for more than 95% of the time;</p> <p><input type="checkbox"/> Over any 12 month period the concentration of total phosphorus shall not exceed 40 mg/litre for more than 99% of the time.</p> <p>From the 1st of July 2012:</p> <p><input type="checkbox"/> Over any 12 month period the concentration of total phosphorus shall not exceed 17 mg/litre for more than 95% of the time;</p> <p><input type="checkbox"/> Over any 12 month period the concentration of total phosphorus shall not exceed 22 mg/litre for more than 99% of the time.</p> <p>f) Soluble Reactive Phosphorus:</p> <p>From the date of the commencement of this consent until 30 June 2012:</p> <p><input type="checkbox"/> Over any 12 month period the concentration of soluble reactive phosphorus shall not exceed 30 mg/litre for more than 95% of the time;</p> <p><input type="checkbox"/> Over any 12 month period the concentration of soluble reactive phosphorus shall not exceed 35 mg/litre for more than 99% of the time.</p>	

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
		From the 1st of July 2012:	
		<input type="checkbox"/> Over any 12 month period the concentration of soluble reactive phosphorus shall not exceed 15 mg/litre for more than 95% of the time;	
		<input type="checkbox"/> Over any 12 month period the concentration of soluble reactive phosphorus shall not exceed 20 mg/litre for more than 99% of the time.	
	Grade 2	Minor non-compliance	18-Aug-08
		Part (a) Low pH (6.4) on 8th May 2008. Parts (b) to (e) full compliance	
	Grade 1	Compliance	26-Jun-09
	Grade 2	Minor non-compliance	06-Oct-09
		Graded incorrectly. There were two reported low pH results for the year, missed by the reporting officer. Minor non-compliance	
5	Technical	<p>The consent holder shall carry out the following monitoring programme at the consent holders expense:</p> <p>a) A sampling station shall be maintained at the outlet of the settlement pond and be accessible to the Council officers, or its agents at all times.</p> <p>b) A representative, flow-proportional, composite sample (sampled continuously over a period of 24 hours) shall be collected from the sampling station, referred to in Condition 5a, at least once per week and tested for the following parameters:</p> <p>i) pH;</p> <p>ii) total phosphorus;</p> <p>iii) soluble reactive phosphorus;</p> <p>iv) fluoride;</p> <p>v) suspended solids</p> <p>Results shall be recorded on a mass per unit volume of discharge basis and the volume of discharge shall also be recorded. The records shall be forwarded to the Council at monthly intervals, along with an assessment of compliance against condition 4.</p> <p>c) A representative, flow-proportional, composite sample (sampled continuously over a period of one week) shall be collected from the sampling station, referred to in Condition 5a, at six monthly intervals and tested for the following parameters:</p> <p>i) total copper</p> <p>ii) total zinc</p> <p>iii) total cadmium</p> <p>iv) total chrome</p> <p>v) total aluminium</p> <p>vi) total sulphur</p>	

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
		<p>Results shall be taken on a mass per unit volume of discharge basis and the volume of discharge taken shall also be recorded. The records shall be forwarded to the Council at six monthly intervals.</p> <p>d) All sampling and surveys shall be carried out by a person suitably qualified and experienced in this field and authorised by the Council (Manager: Regulation).</p> <p>e) All analyses in accordance with conditions of this consent shall be carried out by an independently IANZ accredited laboratory and authorised by the Council (Manager: Regulation).</p> <p>f) The consent holder shall calibrate and operate any meters required for monitoring in accordance with the manufacturer's specifications, or to the reasonable satisfaction of the Chief Executive of the Hawke's Bay Regional Council.</p>	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
6	Technical	<p>Every fourth year starting from the commencement of this consent, the consent holder shall monitor the following components in the receiving environment at their expense:</p> <p>a) the structure of macrofaunal communities to determine both temporal and spatial changes in the community composition. Species diversity, richness, abundance and evenness shall be determined for the benthic macrofauna, and data should be subjected to appropriate multi-variate analyses in relations to chemical and physical measurements.</p> <p>b) sediment quality to determine sediment health, and potential accumulation of contaminants within the sediments.</p> <p>Sediments should be analysed for:</p> <ul style="list-style-type: none"> - total copper - total cadmium - total chromium - total zinc - fluoride - total phosphorus - sulphur - sediment composition - nickel <p>Metal <input type="checkbox"/> <input type="checkbox"/></p> <p>Detection Limit <input type="checkbox"/> <input type="checkbox"/></p>	

□□

Total Copper□□

2 mg/kg (screen)□□

□□

Total Cadmium□□

0.1 mg/kg (screen)□□

□□

Total Chromium□□

2 mg/kg (screen)□□

□□

Total Zinc□□

4 mg/kg (screen)□□

□□

Total Mercury□□

0.1 mg/kg (screen)□□

□□

Total Nickel□□

2 mg/kg (screen)□□

□□

c) receiving water quality to determine whether contaminants of concern are present and in what concentrations.

Receiving water should be analysed for:

- Temperature
- Salinity
- Dissolved oxygen
- pH
- Suspended Solids
- Chlorophyll a
- Ammoniacal Nitrogen
- Nitrate Nitrogen
- Nitrite Nitrogen

Condition No.	Type of Condition	Consent Condition and Compliance Assessment
---------------	-------------------	---

- Nitrate + Nitrite Nitrogen
- Total Nitrogen
- SRP
- TP
- Sulphur
- Fluoride
- Aluminium
- Cadmium
- Chromium
- Copper
- Zinc
- Nickel

Metal□□

Detection Limit□□

□□

Aluminium□□

0.003 mg/L (trace)□□

□□

Cadmium□□

0.00005 mg/L (trace)□□

□□

Chromium□□

0.0005 mg/l (trace)□□

□□

Copper□□

0.0005 mg/l (trace)□□

□□

Zinc□□

0.001 mg/l (trace)□□

□□

Mercury□□

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
		0.00008 mg/l (trace)□□	
		□□	
		Nickel□□	
		0.0005 mg/l (trace)□□	
		□□	
		d) chlorophyll a concentrations as an indicator of potential nutrient enrichment.	
		e) presence/absence of fish species.	
		f) periphyton biomass and taxonomy as an indicator of potential nutrient enrichment.	
		g) undertake Whole Effluent Toxicity Testing to determine the effects of the combined discharge on organisms in the receiving environment on three test species at 100: 1 dilution.	
	Grade 1	Compliance Next report due 2011.	18-Aug-08
	Grade N	Not applicable	26-Jun-09
7	Technical	The consent holder shall submit a monitoring program, designed to meet the requirements of Condition 6, to the satisfaction of the Council (Manager: Environmental Regulation), prior to the receiving environment monitoring occurring in accordance with Condition 7.	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
8	Technical	Within three months of the receiving environment monitoring taking place in accordance with Condition 7, the consent holder shall submit a report to the Hawke's Bay Regional Council detailing results and analysis of the monitoring, and a summary of conclusions.	
	Grade 1	Compliance	18-Aug-08
	Grade 1	Compliance	26-Jun-09
9	Technical	The consent holder shall prepare an annual report for the period of July to June each year, and by the end of July and submit it to the Hawke's Bay Regional Council. The report shall summarise monitoring and compliance to the consent conditions and discuss any non-compliance and recommended necessary actions to achieve compliance.	

Condition No.	Type of Condition	Consent Condition and Compliance Assessment	
	Grade 1	Compliance	18-Aug-08
	Grade N	Not applicable Due July 2009	26-Jun-09

Grading Information

Each consent condition has been classified as either a Environmental or Technical condition.

Environmental conditions:

Environmental conditions set standards/performance limits for a resource consent, or, mitigates an environmental impact of exercising a resource consent.

Examples of environmental conditions are:

- Installation of up-gradient cut-off drains/ placement of disposal fields
- volume limits of discharges
- water take rates and maximum volumes
- discharge or receiving water contaminant limits

Technical conditions:

Technical conditions sets out technical requirements that allows a consent holder to demonstrate or measure that they meet the Environmental performance required by a resource consent, or help specify the activity authorised.

Examples of technical conditions are:

- sampling effluent/ recording discharge volumes / collating submitting data
- providing of reports/ plans/ designs specifications
- notifications, accreditation, authorities submissions for approval by ER Manager
- installation and maintenance of a water meter

You need to comply with all conditions regardless of whether it's a Environmental or Technical condition.